



geoscience LTD
LABORATORY TESTING DIVISION

ORIGINAL

6260-B Marindustry Drive

San Diego, CA 92121

PROPERTY CERTIFICATION

CLIENT: WINCO Technologies
Z.I. des Chatelets
B, ru du Boisillon
22850 TREGUEUX
FRANCE

DATE: April 17, 2007

MATERIAL INVESTIGATED:

Skytech Roof Insulation foil materials

PROPERTY MEASURED:

Infrared Emissivity

MEASUREMENT METHOD:

Following the procedures of ASTM E-408 (C-1371)

RESULTS:*

Infrared Emissivity = 0.05

* Details of the investigation are not included in this Property Certification; the results presented here apply only to the samples tested.

H. F. Poppendiek
CERTIFYING OFFICER: H. F. Poppendiek